

## Table of Contents

Improved Trigger & Actions to Be Able to Use the Output Port of the BioStation 2 .....	1
1. Configure at Device Trigger & Action .....	1
2. Configure at BioStar 2 Global Trigger & Action .....	2
3. Configure at BioStar 2 Door Alarm .....	2
4. Configure at BioStar 2 Zone Alarm .....	2

# Improved Trigger & Actions to Be Able to Use the Output Port of the BioStation 2


As you know, BioStation 2 is the only Suprema device that has a separate TTL Output port. In order to support various installation environments of customers, Suprema improved its function to configure Trigger & Action through the TTL Output port of BioStation 2.

Before using this feature, you should **match both BioStar 2 software and BioStation 2 firmware version** as follows.

- **BioStar 2 SW** : v2.8.3 or above
- **BioStation 2 Firmware** : v1.9.0 or above


## 1. Configure at Device Trigger & Action

- BioStar 2 > Device > BioStation 2 > Advanced > Trigger & Action




## 2. Configure at BioStar 2 Global Trigger & Action

- BioStar 2 > Settings > Trigger & Action




## 3. Configure at BioStar 2 Door Alarm

- BioStar 2 > Door > Alarm



## 4. Configure at BioStar 2 Zone Alarm

- BioStar 2 > Zone > Alarm



From:

<http://kb.supremainc.com/knowledge/> -

Permanent link:

[http://kb.supremainc.com/knowledge/doku.php?id=en:improved\\_trigger\\_actions\\_to\\_be\\_able\\_to\\_use\\_the\\_output\\_port\\_of\\_the\\_biostation\\_2](http://kb.supremainc.com/knowledge/doku.php?id=en:improved_trigger_actions_to_be_able_to_use_the_output_port_of_the_biostation_2)

Last update: 2021/12/17 10:57